



# TEST REPORT

DATE: 03-23-2023

Page 1 of 2

TEST NUMBER: 0295655

<b>CLIENT</b>	Lions Floor
---------------	-------------

<b>TEST METHOD CONDUCTED</b>	ISO 24337 Laminate Floor Coverings - Determination of Geometrical Characteristics
------------------------------	---



DESCRIPTION OF TEST SAMPLE	
<b>IDENTIFICATION</b>	Comfort Heights
<b>COLOR</b>	Country Aura
<b>ROLL NUMBER</b>	SKU: LI-CH07
<b>CONSTRUCTION</b>	Laminate Flooring

## GENERAL PRINCIPLE

The submitted goods were measured to determine geometrical values for size, squareness, straightness, height deviations, and gapping when applied together. All values listed are in mm.

## TEST RESULTS

CHARACTERISTIC		VALUE (mm)					
Thickness		11.775					
Length		1515.313					
Width		235.224					
Straightness		0.042					
Squareness (out of square)		Max:	0.158	Avg:	0.064		
Openings Between Elements		Max:	0.167	Avg:	0.088		
Height Difference Between Elements		Max:	0.132	Avg:	0.075		
Width Flatness	Max:	0.190	0.081%	Avg	0.157	0.067%	Concave
Length Flatness	Max:	0.412	0.027%	Avg	0.331	0.022%	Concave

APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.



# TEST REPORT

DATE: 03-23-2023

Page 2 of 2


TEST NUMBER: 0295655

<b>CLIENT</b>	Lions Floor
---------------	-------------

<b>TEST METHOD CONDUCTED</b>	ISO 24337 Laminate Floor Coverings - Determination of Geometrical Characteristics
------------------------------	---



DESCRIPTION OF TEST SAMPLE	
<b>IDENTIFICATION</b>	Comfort Heights
<b>COLOR</b>	Country Aura
<b>ROLL NUMBER</b>	SKU: LI-CH07
<b>CONSTRUCTION</b>	Laminate Flooring



APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.