



TEST REPORT

DATE: 09-06-2022

Page 1 of 1

TEST NUMBER: 0289067

CLIENT	Lions Floor
---------------	-------------

TEST METHOD CONDUCTED	ISO 4918 Resilient, Textile and Laminate Floor Coverings - Castor Chair Test
------------------------------	--



DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	Lions Floor Lone Star Spirit Collection(Packaged in Red/White/Blue Boxes)
COLOR	LI-TS106 Saddle Brownie
CONSTRUCTION	SPC
BACKING	EVA

GENERAL PRINCIPLE

This test is designed to determine what effect the action of rolling traffic has on a particular flooring surface. The sample is subjected to the reciprocating action of a chair base which is loaded with weight. The chair castors are set to cause a circular cycling motion resulting in a circle shaped wear pattern.

TEST RESULTS

NUMBER OF CYCLES	APPEARANCE RATING
1,850	Testing was stopped due to seam separation caused by broken locking mechanisms.

APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.