

## **TEST REPORT**

CLIENT	Lions Floor
--------	-------------

	ASTM F2	199 St	andard	Test Method	d fo	r Determir	ning D	imen	sional
TEST METHOD CONDUCTED	Stability Exposure		_	Properties	of	Resilient	Floor	Tile	after



DESCRIPTION OF TEST SAMPLE				
IDENTIFICATION	Uptown: 2.5mm/12mil LVP			
COLOR	East Aspen			
ROLL NUMBER	SKU: LI-UP07			
CONSTRUCTION	LVP			

## **GENERAL PRINCIPLE**

This test method is intended for use in determining the linear change of resilient flooring after being exposed to heat. The dimensional change over 12 inches is reported as the dimensional stability.

## **TEST RESULTS**


					Initial		Final
Replicate	Direction	Temp	Dimensional Change		Curl		Curl
#1	Length	80° C	-0.007 inch/12 inches (-0.06%)	0.00 inch (	0.00 mm)	0.00 inch (	0.00 mm)
	Width	80° C	-0.003 inch/12 inches (-0.03%)				
#2	Length	80° C	-0.009 inch/12 inches (-0.07%)	0.00 inch (	0.00 mm)	0.00 inch (	0.00 mm)
	Width	80° C	0.000 inch/12 inches (0.00%)				
#3	Length	80° C	-0.009 inch/12 inches (-0.07%)	0.00 inch (	0.00 mm)	0.00 inch (	0.00 mm)
	Width	80° C	-0.003 inch/12 inches (-0.03%)				

APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.

714 Glenwood Place Dalton, GA 30721 Phone: 706-226-3283 Fax: 706-226-6787 email: protest@optilink.us

Lang atleny



## **TEST REPORT**

CLIENT	Lions Floor
--------	-------------

	ASTM F2	199 St	andard	Test Method	d fo	r Determir	ning D	imen	sional
TEST METHOD CONDUCTED	Stability	and	Curling	<b>Properties</b>	of	Resilient	Floor	Tile	after
	Exposure	to He	eat						



DESCRIPTION OF TEST SAMPLE			
IDENTIFICATION	Uptown: 2.5mm/12mil LVP		
COLOR	East Aspen		
ROLL NUMBER	SKU: LI-UP07		
CONSTRUCTION	LVP		



APPROVED BY:

Lang aslung

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.

714 Glenwood Place Dalton, GA 30721 Phone: 706-226-3283 Fax: 706-226-6787 email: protest@optilink.us